

MISSISSIPPI STATE DEPARTMENT OF HEALTH

BUREAU OF PUBLIC WATER SUPPLY

CALENDAR YEAR 2010 CONSUMER CONFIDENCE REPORT CERTIFICATION FORM

Town of Hatley Water Public Water Supply Name

List PWS ID #s for all Water Systems Covered by this CCR

The F confid must b	deral Safe Drinking Water Act requires each <i>community</i> public water system to develop and distribute a consumer nce report (CCR) to its customers each year. Depending on the population served by the public water system, this CCR mailed to the customers, published in a newspaper of local circulation, or provided to the customers upon request.
Please	Answer the Following Questions Regarding the Consumer Confidence Report
B	Customers were informed of availability of CCR by: (Attach copy of publication, water bill or other)
	Advertisement in local paper On water bills Other
	Date customers were informed:/_/
	CCR was distributed by mail or other direct delivery. Specify other direct delivery methods:
	Date Mailed/Distributed: / /
Ü	CCR was published in local newspaper. (Attach copy of published CCR or proof of publication)
	Name of Newspaper: Monroe County Shopper
	Date Published: _5 /25/ 11
	CCR was posted in public places. (Attach list of locations)
	Date Posted: / /
	CCR was posted on a publicly accessible internet site at the address: www
CERT	FICATION
onsiste Departn	certify that a consumer confidence report (CCR) has been distributed to the customers of this public water system in and manner identified above. I further certify that the information included in this CCR is true and correct and is the twith the water quality monitoring data provided to the public water system officials by the Mississippi State of Health, Bureau of Public Water Supply. The provided to the public water system officials by the Mississippi State water system, which was a supply that the customers of this public water system in the customers of this public water system of the customers of the custom
	Mail Completed Form to: Bureau of Public Water Supply/P.O. Box 1700/Jackson, MS 39215 Phone: 601-576-7518

570 East Woodrow Wilson • Post Office Box 1700 • Jackson, Mississippi 39215-1700 601/576-7634 • Fax 601/576-7931 • www.HealthyMS.com

Equal Opportunity In Employment/Service

2010 Annual Drinking Water Quality Report Town of Hatley Water Department PWS#: 0480008 May 2011

We're pleased to present to you this year's Annual Quality Water Report. This report is designed to inform you about the quality water and services we deliver to you every day. Our constant goal is to provide you with a safe and dependable supply of drinking water. We want you to understand the efforts we make to continually improve the water treatment process and protect our water resources. We are committed to ensuring the quality of your water. Our water source is from wells drawing from the Gordo Aquifer.

The source water assessment has been completed for our public water system to determine the overall susceptibility of its drinking water supply to identified potential sources of contamination. The general susceptibility rankings assigned to each well of this system are provided immediately below. A report containing detailed information on how the susceptibility determinations were made has been furnished to our public water system and is available for viewing upon request. The wells for the Town of Hatley have received a moderate susceptibility ranking to contamination.

If you have any questions about this report or concerning your water utility, please contact Harold West at 662.256.7245. We want our valued customers to be informed about their water utility. If you want to learn more, please attend any of our regularly scheduled meetings. They are held on the first Tuesday of the month at 7:00 PM at the Town Hall Board Room.

We routinely monitor for constituents in your drinking water according to Federal and State laws. This table below lists all of the drinking water contaminants that we detected during for the period of January 1st to December 31st, 2010. In cases where monitoring wasn't required in 2010, the table reflects the most recent results. As water travels over the surface of land or underground, it dissolves naturally occurring minerals and, in some cases, radioactive materials and can pick up substances or contaminants from the presence of animals or from human activity; microbial contaminants, such as viruses and bacteria, that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife; inorganic contaminants, such as salts and metals, which can be naturally occurring or result from urban storm-water runoff, industrial, or domestic wastewater discharges, oil and gas production, mining, or farming; pesticides and herbicides, which may come from a variety of sources such as agriculture, urban storm-water runoff, and residential uses; organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations and septic systems; radioactive contaminants, which can be naturally occurring or be the result of oil and gas production and mining activities. In order to ensure that tap water is safe to drink, EPA prescribes regulations that limit the amount of certain contaminants in water provided by public water systems. All drinking water, including bottled drinking water, may be reasonably expected to contain at least small amounts of some constituents. It's important to remember that the presence of these constituents does not necessarily indicate that the water poses a health risk.

In this table you will find many terms and abbreviations you might not be familiar with. To help you better understand these terms we've provided the following definitions:

Action Level - the concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

Maximum Contaminant Level (MCL) - The "Maximum Allowed" (MCL) is the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

Maximum Contaminant Level Goal (MCLG) - The "Goal" (MCLG) is the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

Maximum Residual Disinfectant Level (MRDL) – The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control microbial contaminants.

Maximum Residual Disinfectant Level Goal (MRDLG) – The level of a drinking water disinfectant below which there is no known or expected risk of health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

Parts per million (ppm) or Milligrams per liter (mg/l) - one part per million corresponds to one minute in two years or a single penny in \$10,000.

Parts per billion (ppb) or Micrograms per liter - one part per billion corresponds to one minute in 2,000 years, or a single penny in \$10,000,000.

				TEST R	ESULI	$\Gamma \mathbf{S}$		
Contaminant	Violatio n Y/N	Date Collected	Level Detected	Range of Detects or # of Samples Exceeding MCL/ACL	Unit Measure -ment	MCLG	MCL	Likely Source of Contamination

10. Barium	N	2008*	.009	No Range	ppm	2	2	Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits
17. Lead	N	2008*	1	0	ppb	0	AL=15	Corrosion of household plumbing systems, erosion of natural deposits
13. Chromium	N	2008*	.658	No Range	ppb	100	100	Discharge from steel and pulp mills; erosion of natural deposits
Disinfection	on By	-Produc	ts					
Chlorine	N	2010	.83	.89	ppm	0	MDRL =	Water additive used to control microbes

^{*} Most recent sample. No sample required for 2010.

As you can see by the table, our system had no contaminant violations. We're proud that your drinking water meets or exceeds all Federal and State requirements. We have learned through our monitoring and testing that some constituents have been detected however the EPA has determined that your water IS SAFE at these levels.

We are required to monitor your drinking water for specific constituents on a monthly basis. Results of regular monitoring are an indicator of whether or not our drinking water meets health standards. We did complete the monitoring requirements for bacteriological sampling that showed no coliform present. In an effort to ensure systems complete all monitoring requirements, MSDH now notifies systems of any missing samples prior to the end of the compliance period.

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Our Water Association is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at http://www.epa.gov/safewater/lead. The Mississippi State Department of Health Public Health Laboratory offers lead testing. Please contact 601.576.7582 if you wish to have your water tested.

All sources of drinking water are subject to potential contamination by substances that are naturally occurring or man made. These substances can be microbes, inorganic or organic chemicals and radioactive substances. All drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline at 1-800-426-4791.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by cryptosporidium and other microbiological contaminants are available from the Safe Drinking Water Hotline 1-800-426-4791.

The Town of Hatley Water Department works around the clock to provide top quality water to every tap. We ask that all our customers help us protect our water sources, which are the heart of our community, our way of life and our children's future.

PROOF OF PUBLICATION

STATE OF MISSISSIPPI COUNTY OF MONROE
Before the undersigned, a Notary Public in
And for said state and county, <u>Jeff Boozer</u> , editor, publisher and manager of The Monroe County Shopper, an advertising medium in Amory, in said County and state makes oath that the Town of Hatley Water Department
Of which the article hereunto attached is a true copy, was published in said advertising medium as follows:
Edition #1569 Dated25-May 201
And I hereby certify that the issue above mentioned has been examined by me, and I find the publication therof to have been duly made, and that The Monroe County Shopper has been established, published and had a bonafide circulation in said town, county and state for more than one year next preceding the first insertion of the article described herein. Editor, publisher and manager
Sworn to and subscribed before me this
(Seal) ID No 30151 NOTARY PUBLIC Comm Expires July 24, 2014 My commission expres
Cost of Publication
Cost of 1 noncanon

\$150.00

Contaminant	Violation Y/N	Date Collected	Level Detected	Frange of Detects ox # of Samples Exceeding MCL/ACL	Unit Measure -ment	MCLG	MCL	Likely Source of Contemination
Inorganic	Contar	ninants						
10. Barium	N	2003*	.009	No Range	ppm	2	2	Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits
17. Lead	in i	2008	1	0"	ppb	0	AL=15	Corrosion of household plumbing systems, erosion of natural deposits
13. Chromium	N	2008	.658	No Range	ppb *	100	100	Discharge from steel and pulp mills; erosion of natural deposits



Thank You The family of Acker Lackie would like to thank all their kind and generous friends for their prayers, visits, phone calls and support we received. A thank you to Bro. Mark Thornton and Bro. Rickey Jones for their comforting words. Also to Benny & Linda Davis & Don for the beautiful music. A special thanks goes out to Dr. Hayes, Dr. Barker and Lisa Cooper and to all the staff at Pioncer Hospital and Kenny Tisdale and staff at Tisdale-Lann Memorial Funeral Home, we are fortunate to have places that care and help like they helped us in our time of need. A special thanks goes out to Sidney Bean and Frances Holly for their daily visits. Also to the caregivers, Roosevelt Garth and Cynthia Williams and to our law enforcement officers for their support. It is a great comfort in a time of sadness to receive such heartfelt expression of sympathy from so many. Love to all, Ila Dean, Darnell, Libby, Kennetb, Ann, Rodger and Family